

2026 Irrigation System Services RFP

Questions and Answers

Q: Do you know the number of water connections and controllers?

A: There is one primary water main located in the State House that feeds two individual control centers. There are two controllers.

Q: What brand controller? And/ or system (Hunter, Rainbird, Toro, Baseline etc...)

A: The main controller is a Hunter ICC2 and is located inside the State House. The secondary control is a Hunter PRO C and is located in an external service area on the grounds immediately to the south of the State House.

Q: Would you know the total number of zones?

A: The main control panel runs 23 zones. The secondary control panel runs 10 hard wired zones.

Q: Is there an as-built for the irrigation system

A: As built plans exist onsite